

Our Ref: HL/M100442

15<sup>th</sup> February 2011

Klamflex Pipe Couplings (Pty) Ltd.  
52 Fransen Street,  
Chandor,  
Krugersdorp,  
Gauteng,  
South Africa,  
1743

Dear Sir

**WATER REGULATIONS ADVISORY SCHEME  
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"**

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

**RUBBERS – ETHYLENE PROPYLENE DIENE MONOMER (EPDM) – MATERIAL ONLY 5365**

R171WM. Black coloured EPDM rubber sheet material. Shore hardness 75. Tested in-radius size of 1mm. For use with water up to 60°C.

Test Report: MAT/LAB 154B

0905526


**KLAMFLEX PIPE COUPLINGS (PTY) LTD.**

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Material" or "WRAS - Approved Material". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in May 2014.

Yours faithfully



Hannah Lewis  
WRAS Approvals Administrator  
Water Regulations Advisory Scheme